

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 18)**

Water Level of the accumulated water (at 7:00 on December 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,053 mm (44 mm increase since 16:00 on December 17)	O.P.+ 3,109 mm (10 mm increase since 16:00 on December 17)	—
	Water level of Turbine Building	O.P.+ 2,784 mm (3 mm increase since 16:00 on December 17)	O.P.+ 3,074 mm (39 mm increase since 16:00 on December 17)	O.P.+ 3,009 mm (10 mm increase since 16:00 on December 17)	O.P.+ 2,986 mm (10 mm increase since 16:00 on December 17)
	Water level of Reactor Building	O.P.+ 4,163 mm (9 mm increase since 16:00 on December 17)	O.P.+ 3,332 mm (41 mm increase since 16:00 on December 17)	O.P.+ 3,195 mm (11 mm increase since 16:00 on December 17)	O.P.+ 2,987 mm (10 mm increase since 16:00 on December 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,631 mm (Increase from initial level:4,848 mm, 4 mm increase since 16:00 on December 17) O.P.+ 2,449 mm (Increase from initial level:3,175 mm, 370 mm decrease since 16:00 on December 17) O.P.+ 4,272 mm (Water level from floor:476 mm, 1 mm increase since 16:00 on December 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:05 on December 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.