

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 19)**

Water Level of the accumulated water (at 7:00 on December 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,118 mm (38 mm increase since 16:00 on December 18)	O.P.+ 3,094 mm (15 mm decrease since 16:00 on December 18)	—
	Water level of Turbine Building	O.P.+ 2,787 mm (1 mm increase since 16:00 on December 18)	O.P.+ 3,130 mm (33 mm increase since 16:00 on December 18)	O.P.+ 2,971 mm (34 mm decrease since 16:00 on December 18)	O.P.+ 2,982 mm (9 mm decrease since 16:00 on December 18)
	Water level of Reactor Building	O.P.+ 4,177 mm (8 mm increase since 16:00 on December 18)	O.P.+ 3,386 mm (32 mm increase since 16:00 on December 18)	O.P.+ 3,158 mm (38 mm decrease since 16:00 on December 18)	O.P.+ 2,986 mm (7 mm decrease since 16:00 on December 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,634 mm (Increase from initial level:4,851 mm, 2 mm increase since 16:00 on December 18) O.P.+ 2,286 mm (Increase from initial level:3,012 mm, No change since 16:00 on December 18) O.P.+ 4,272 mm (Water level from floor:476 mm, No change since 16:00 on December 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:05 on December 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.