

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on December 19)**

Water Level of the accumulated water (at 16:00 on December 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,139 mm (21 mm increase since 7:00 on December 19)	O.P.+ 3,086 mm (8 mm decrease since 7:00 on December 19)	—
	Water level of Turbine Building	O.P.+ 2,789 mm (2 mm increase since 7:00 on December 19)	O.P.+ 3,149 mm (19 mm increase since 7:00 on December 19)	O.P.+ 2,953 mm (18 mm decrease since 7:00 on December 19)	O.P.+ 2,974 mm (8 mm decrease since 7:00 on December 19)
	Water level of Reactor Building	O.P.+ 4,183 mm (6 mm increase since 7:00 on December 19)	O.P.+ 3,401 mm (15 mm increase since 7:00 on December 19)	O.P.+ 3,142 mm (16 mm decrease since 7:00 on December 19)	O.P.+ 2,980 mm (6 mm decrease since 7:00 on December 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,637 mm (Increase from initial level:4,854 mm, 3 mm increase since 7:00 on December 19) O.P.+ 2,286 mm (Increase from initial level:3,012 mm, No change since 7:00 on December 19) O.P.+ 4,271 mm (Water level from floor:475 mm, 1 mm decrease since 7:00 on December 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:05 on December 12   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.