

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 20)**

Water Level of the accumulated water (at 7:00 on December 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,175 mm (36 mm increase since 16:00 on December 19)	O.P.+ 3,070 mm (16 mm decrease since 16:00 on December 19)	—
	Water level of Turbine Building	O.P.+ 2,791 mm (2 mm increase since 16:00 on December 19)	O.P.+ 3,180 mm (31 mm increase since 16:00 on December 19)	O.P.+ 2,933 mm (20 mm decrease since 16:00 on December 19)	O.P.+ 2,958 mm (16 mm decrease since 16:00 on December 19)
	Water level of Reactor Building	O.P.+ 4,190 mm (7 mm increase since 16:00 on December 19)	O.P.+ 3,434 mm (33 mm increase since 16:00 on December 19)	O.P.+ 3,116 mm (26 mm decrease since 16:00 on December 19)	O.P.+ 2,964 mm (16 mm decrease since 16:00 on December 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,638 mm (Increase from initial level:4,855 mm, 1 mm increase since 16:00 on December 19) O.P.+ 2,284 mm (Increase from initial level:3,010 mm, 2 mm decrease since 16:00 on December 19) O.P.+ 4,271 mm (Water level from floor:475 mm, No change since 16:00 on December 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:38 on December 20 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:38 AM on December 20, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.