

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on December 20)**

Water Level of the accumulated water (at 16:00 on December 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,196 mm (21 mm increase since 7:00 on December 20)	O.P.+ 3,060 mm (10 mm decrease since 7:00 on December 20)	—
	Water level of Turbine Building	O.P.+ 2,791 mm (No change since 7:00 on December 20)	O.P.+ 3,198 mm (18 mm increase since 7:00 on December 20)	O.P.+ 2,917 mm (16 mm decrease since 7:00 on December 20)	O.P.+ 2,948 mm (10 mm decrease since 7:00 on December 20)
	Water level of Reactor Building	O.P.+ 4,195 mm (5 mm increase since 7:00 on December 20)	O.P.+ 3,452 mm (18 mm increase since 7:00 on December 20)	O.P.+ 3,102 mm (14 mm decrease since 7:00 on December 20)	O.P.+ 2,956 mm (8 mm decrease since 7:00 on December 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,640 mm (Increase from initial level:4,857 mm, 2 mm increase since 7:00 on December 20) O.P.+ 2,389 mm (Increase from initial level:3,115 mm, 105 mm increase since 7:00 on December 20) O.P.+ 4,272 mm (Water level from floor:476 mm, 1 mm increase since 7:00 on December 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:03 on December 20 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:38 AM on December 20, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 11:45 AM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 12:03 PM on the same day.				

For quick publication of the data of water level, values are provided as reference values.