

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 21)**

Water Level of the accumulated water (at 7:00 on December 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,230 mm (34 mm increase since 16:00 on December 20)	O.P.+ 3,042 mm (18 mm decrease since 16:00 on December 20)	—
	Water level of Turbine Building	O.P.+ 2,793 mm (2 mm increase since 16:00 on December 20)	O.P.+ 3,228 mm (30 mm increase since 16:00 on December 20)	O.P.+ 2,897 mm (20 mm decrease since 16:00 on December 20)	O.P.+ 2,931 mm (17 mm decrease since 16:00 on December 20)
	Water level of Reactor Building	O.P.+ 4,205 mm (10 mm increase since 16:00 on December 20)	O.P.+ 3,480 mm (28 mm increase since 16:00 on December 20)	O.P.+ 3,080 mm (22 mm decrease since 16:00 on December 20)	O.P.+ 2,939 mm (17 mm decrease since 16:00 on December 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,642 mm (Increase from initial level:4,859 mm, 2 mm increase since 16:00 on December 20) O.P.+ 2,378 mm (Increase from initial level:3,104 mm, 11 mm decrease since 16:00 on December 20) O.P.+ 4,272 mm (Water level from floor:476 mm, No change since 16:00 on December 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:03 on December 20   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.