

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on December 21)**

Water Level of the accumulated water (at 16:00 on December 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,237 mm (7 mm increase since 7:00 on December 21)	O.P.+ 3,032 mm (10 mm decrease since 7:00 on December 21)	—
	Water level of Turbine Building	O.P.+ 2,795 mm (2 mm increase since 7:00 on December 21)	O.P.+ 3,234 mm (6 mm increase since 7:00 on December 21)	O.P.+ 2,896 mm (1 mm decrease since 7:00 on December 21)	O.P.+ 2,921 mm (10 mm decrease since 7:00 on December 21)
	Water level of Reactor Building	O.P.+ 4,212 mm (7 mm increase since 7:00 on December 21)	O.P.+ 3,495 mm (15 mm increase since 7:00 on December 21)	O.P.+ 3,074 mm (6 mm decrease since 7:00 on December 21)	O.P.+ 2,929 mm (10 mm decrease since 7:00 on December 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,643 mm (Increase from initial level:4,860 mm, 1 mm increase since 7:00 on December 21) O.P.+ 2,375 mm (Increase from initial level:3,101 mm, 3 mm decrease since 7:00 on December 21) O.P.+ 4,272 mm (Water level from floor:476 mm, No change since 7:00 on December 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:52 on December 21)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:03 on December 20 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.