

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 25)**

Water Level of the accumulated water (at 7:00 on December 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,006 mm (37 mm decrease since 16:00 on December 24)	O.P.+ 3,087 mm (8 mm increase since 16:00 on December 24)	—
	Water level of Turbine Building	O.P.+ 2,804 mm (No change since 16:00 on December 24)	O.P.+ 3,033 mm (33 mm decrease since 16:00 on December 24)	O.P.+ 2,987 mm (14 mm increase since 16:00 on December 24)	O.P.+ 2,961 mm (9 mm increase since 16:00 on December 24)
	Water level of Reactor Building	O.P.+ 4,182 mm (23 mm decrease since 16:00 on December 24)	O.P.+ 3,304 mm (31 mm decrease since 16:00 on December 24)	O.P.+ 3,167 mm (9 mm increase since 16:00 on December 24)	O.P.+ 2,964 mm (9 mm increase since 16:00 on December 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,657 mm (Increase from initial level:4,874 mm, 1 mm increase since 16:00 on December 24) O.P.+ 2,339 mm (Increase from initial level:3,065 mm, 4 mm decrease since 16:00 on December 24) O.P.+ 4,272 mm (Water level from floor:476 mm, 1 mm decrease since 16:00 on December 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:52 on December 21)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:03 on December 20   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.