

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on December 25)**

Water Level of the accumulated water (at 16:00 on December 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,986 mm (20 mm decrease since 7:00 on December 25)	O.P.+ 3,093 mm (6 mm increase since 7:00 on December 25)	—
	Water level of Turbine Building	O.P.+ 2,805 mm (1 mm increase since 7:00 on December 25)	O.P.+ 3,015 mm (18 mm decrease since 7:00 on December 25)	O.P.+ 2,987 mm (No change since 7:00 on December 25)	O.P.+ 2,967 mm (6 mm increase since 7:00 on December 25)
	Water level of Reactor Building	O.P.+ 4,168 mm (14 mm decrease since 7:00 on December 25)	O.P.+ 3,289 mm (15 mm decrease since 7:00 on December 25)	O.P.+ 3,174 mm (7 mm increase since 7:00 on December 25)	O.P.+ 2,970 mm (6 mm increase since 7:00 on December 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,660 mm (Increase from initial level:4,877 mm, 3 mm increase since 7:00 on December 25) O.P.+ 2,341 mm (Increase from initial level:3,067 mm, 2 mm increase since 7:00 on December 25) O.P.+ 4,271 mm (Water level from floor:475 mm, 1 mm decrease since 7:00 on December 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:52 on December 21)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building Temporary Tank Transfer Completed (From 10:00 on December 25, To 15:00 on December 25)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:03 on December 20 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.