

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 27)**

Water Level of the accumulated water (at 7:00 on December 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,019 mm (47 mm increase since 16:00 on December 26)	O.P.+ 3,081 mm (12 mm decrease since 16:00 on December 26)	—
	Water level of Turbine Building	O.P.+ 2,809 mm (No change since 16:00 on December 26)	O.P.+ 3,042 mm (40 mm increase since 16:00 on December 26)	O.P.+ 2,944 mm (33 mm decrease since 16:00 on December 26)	O.P.+ 2,965 mm (13 mm decrease since 16:00 on December 26)
	Water level of Reactor Building	O.P.+ 4,103 mm (22 mm decrease since 16:00 on December 26)	O.P.+ 3,299 mm (38 mm increase since 16:00 on December 26)	O.P.+ 3,133 mm (35 mm decrease since 16:00 on December 26)	O.P.+ 2,970 mm (10 mm decrease since 16:00 on December 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,666 mm (Increase from initial level:4,883 mm, 2 mm increase since 16:00 on December 26) O.P.+ 2,337 mm (Increase from initial level:3,063 mm, 1 mm decrease since 16:00 on December 26) O.P.+ 4,271 mm (Water level from floor:475 mm, No change since 16:00 on December 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:33 on December 27 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 7:33 AM on December 27, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.