

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on December 28)**

Water Level of the accumulated water (at 7:00 on December 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,091 mm (38 mm increase since 16:00 on December 27)	O.P.+ 3,054 mm (18 mm decrease since 16:00 on December 27)	—
	Water level of Turbine Building	O.P.+ 2,726 mm (1 mm increase since 16:00 on December 27)	O.P.+ 3,108 mm (31 mm increase since 16:00 on December 27)	O.P.+ 2,903 mm (29 mm decrease since 16:00 on December 27)	O.P.+ 2,939 mm (16 mm decrease since 16:00 on December 27)
	Water level of Reactor Building	O.P.+ 4,095 mm (2 mm decrease since 16:00 on December 27)	O.P.+ 3,363 mm (35 mm increase since 16:00 on December 27)	O.P.+ 3,092 mm (23 mm decrease since 16:00 on December 27)	O.P.+ 2,946 mm (16 mm decrease since 16:00 on December 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,671 mm (Increase from initial level:4,888 mm, 2 mm increase since 16:00 on December 27) O.P.+ 2,655 mm (Increase from initial level:3,381 mm, 2 mm decrease since 16:00 on December 27) O.P.+ 4,271 mm (Water level from floor:475 mm, No change since 16:00 on December 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:49 on December 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.