

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on December 28)**

Water Level of the accumulated water (at 16:00 on December 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,114 mm (23 mm increase since 7:00 on December 28)	O.P.+ 3,043 mm (11 mm decrease since 7:00 on December 28)	—
	Water level of Turbine Building	O.P.+ 2,727 mm (1 mm increase since 7:00 on December 28)	O.P.+ 3,128 mm (20 mm increase since 7:00 on December 28)	O.P.+ 2,895 mm (8 mm decrease since 7:00 on December 28)	O.P.+ 2,929 mm (10 mm decrease since 7:00 on December 28)
	Water level of Reactor Building	O.P.+ 4,099 mm (4 mm increase since 7:00 on December 28)	O.P.+ 3,384 mm (21 mm increase since 7:00 on December 28)	O.P.+ 3,078 mm (14 mm decrease since 7:00 on December 28)	O.P.+ 2,937 mm (9 mm decrease since 7:00 on December 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,673 mm (Increase from initial level:4,890 mm, 2 mm increase since 7:00 on December 28) O.P.+ 2,640 mm (Increase from initial level:3,366 mm, 15 mm decrease since 7:00 on December 28) O.P.+ 4,271 mm (Water level from floor:475 mm, No change since 7:00 on December 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:49 on December 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.