

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 4)**

Water Level of the accumulated water (at 16:00 on January 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,927 mm (19 mm decrease since 7:00 on January 4)	O.P.+ 3,073 mm (6 mm increase since 7:00 on January 4)	—
	Water level of Turbine Building	O.P.+ 2,737 mm (1 mm increase since 7:00 on January 4)	O.P.+ 2,963 mm (18 mm decrease since 7:00 on January 4)	O.P.+ 2,962 mm (7 mm increase since 7:00 on January 4)	O.P.+ 2,941 mm (5 mm increase since 7:00 on January 4)
	Water level of Reactor Building	O.P.+ 4,135 mm (17 mm decrease since 7:00 on January 4)	O.P.+ 3,238 mm (18 mm decrease since 7:00 on January 4)	O.P.+ 3,150 mm (7 mm increase since 7:00 on January 4)	O.P.+ 2,947 mm (4 mm increase since 7:00 on January 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,702 mm (Increase from initial level:4,919 mm, 2 mm increase since 7:00 on January 4) O.P.+ 2,444 mm (Increase from initial level:3,170 mm, 5 mm decrease since 7:00 on January 4) O.P.+ 4,272 mm (Water level from floor:476 mm, No change since 7:00 on January 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:45 on December 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:49 on December 27   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.