

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 7)**

Water Level of the accumulated water (at 7:00 on January 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,890 mm (50 mm increase since 16:00 on January 6)	O.P.+ 3,078 mm (16 mm decrease since 16:00 on January 6)	—
	Water level of Turbine Building	O.P.+ 2,739 mm (1 mm increase since 16:00 on January 6)	O.P.+ 2,931 mm (45 mm increase since 16:00 on January 6)	O.P.+ 2,941 mm (39 mm decrease since 16:00 on January 6)	O.P.+ 2,960 mm (9 mm decrease since 16:00 on January 6)
	Water level of Reactor Building	O.P.+ 4,009 mm (22 mm decrease since 16:00 on January 6)	O.P.+ 3,190 mm (36 mm increase since 16:00 on January 6)	O.P.+ 3,134 mm (40 mm decrease since 16:00 on January 6)	O.P.+ 2,967 mm (4 mm decrease since 16:00 on January 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,715 mm (Increase from initial level:4,932 mm, 1 mm increase since 16:00 on January 6) O.P.+ 2,411 mm (Increase from initial level:3,137 mm, 6 mm decrease since 16:00 on January 6) O.P.+ 4,272 mm (Water level from floor:476 mm, No change since 16:00 on January 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:49 on December 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.