

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 8)**

Water Level of the accumulated water (at 7:00 on January 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,959 mm (40 mm increase since 16:00 on January 7)	O.P.+ 3,051 mm (18 mm decrease since 16:00 on January 7)	—
	Water level of Turbine Building	O.P.+ 2,739 mm (No change since 16:00 on January 7)	O.P.+ 2,989 mm (34 mm increase since 16:00 on January 7)	O.P.+ 2,901 mm (24 mm decrease since 16:00 on January 7)	O.P.+ 2,933 mm (18 mm decrease since 16:00 on January 7)
	Water level of Reactor Building	O.P.+ 4,004 mm (1 mm decrease since 16:00 on January 7)	O.P.+ 3,250 mm (35 mm increase since 16:00 on January 7)	O.P.+ 3,092 mm (25 mm decrease since 16:00 on January 7)	O.P.+ 2,944 mm (13 mm decrease since 16:00 on January 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,719 mm (Increase from initial level:4,936 mm, 4 mm increase since 16:00 on January 7) O.P.+ 2,401 mm (Increase from initial level:3,127 mm, 5 mm decrease since 16:00 on January 7) O.P.+ 4,272 mm (Water level from floor:476 mm, No change since 16:00 on January 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:25 on January 8 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	– At 8:25 AM on January 8, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.