Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 8)

		Unit 1	Unit 2	Unit 3	Unit 4	
Water Level of the accumulated water (at 16:00 on January 8)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,983 mm (24 mm increase since 7:00 on January 8)	O.P.+ 3,041 mm (10 mm decrease since 7:00 on January 8)		
	Water level of Turbine Building	O.P.+ 2,739 mm (No change since 7:00 on January 8)	O.P.+ 3,009 mm (20 mm increase since 7:00 on January 8)	O.P.+ 2,887 mm (14 mm decrease since 7:00 on January 8)	O.P.+ 2,923 mm (10 mm decrease since 7:00 on January 8)	
	Water level of Reactor Building	O.P.+ 4,009 mm (5 mm increase since 7:00 on January 8)	O.P.+ 3,271 mm (21 mm increase since 7:00 on January 8)	O.P.+ 3,078 mm (14 mm decrease since 7:00 on January 8)	O.P.+ 2,933 mm (11 mm decrease since 7:00 on January 8)	
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building	O.P.+ 3,720 mm (Increase from initial level:4,937 mm, 1 mm increase since 7:00 on January 8)			
		High Temperature Incinerator Building	O.P.+ 2,578 mm (Increase from initial level:3,304 mm, 177 mm increase since 7:00 on January 8)			
		On-site Bunker Building	O.P.+ 4,272 mm (Water level from floor:476 mm, No change since 7:00 on January 8)			
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4	
		_	_	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)		
		Unit 5 and 6				
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:33 on January 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance				
Notes		8:25 AM on January 8, the second cesium absorption apparatus (SARRY) was temporarily suspended for filter cleaning. At 12:50 PM on the same day, the apparatus restarted after the cleaning was completed. At 1:33 PM on the same day, the steady flow rate was achieved.				
For quick publication of the data of water level, values are provided as reference values						