

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 9)**

Water Level of the accumulated water (at 7:00 on January 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,018 mm (35 mm increase since 16:00 on January 8)	O.P.+ 3,024 mm (17 mm decrease since 16:00 on January 8)	—
	Water level of Turbine Building	O.P.+ 2,740 mm (1 mm increase since 16:00 on January 8)	O.P.+ 3,040 mm (31 mm increase since 16:00 on January 8)	O.P.+ 2,867 mm (20 mm decrease since 16:00 on January 8)	O.P.+ 2,905 mm (18 mm decrease since 16:00 on January 8)
	Water level of Reactor Building	O.P.+ 4,023 mm (14 mm increase since 16:00 on January 8)	O.P.+ 3,302 mm (31 mm increase since 16:00 on January 8)	O.P.+ 3,057 mm (21 mm decrease since 16:00 on January 8)	O.P.+ 2,918 mm (15 mm decrease since 16:00 on January 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,723 mm (Increase from initial level:4,940 mm, 3 mm increase since 16:00 on January 8) O.P.+ 2,618 mm (Increase from initial level:3,344 mm, 40 mm increase since 16:00 on January 8) O.P.+ 4,272 mm (Water level from floor:476 mm, No change since 16:00 on January 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:33 on January 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.