

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 10)**

Water Level of the accumulated water (at 7:00 on January 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,078 mm (36 mm increase since 16:00 on January 9)	O.P.+ 2,997 mm (16 mm decrease since 16:00 on January 9)	—
	Water level of Turbine Building	O.P.+ 2,741 mm (1 mm increase since 16:00 on January 9)	O.P.+ 3,090 mm (31 mm increase since 16:00 on January 9)	O.P.+ 2,835 mm (20 mm decrease since 16:00 on January 9)	O.P.+ 2,877 mm (18 mm decrease since 16:00 on January 9)
	Water level of Reactor Building	O.P.+ 4,054 mm (19 mm increase since 16:00 on January 9)	O.P.+ 3,352 mm (30 mm increase since 16:00 on January 9)	O.P.+ 3,025 mm (19 mm decrease since 16:00 on January 9)	O.P.+ 2,890 mm (20 mm decrease since 16:00 on January 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,726 mm (Increase from initial level:4,943 mm, 2 mm increase since 16:00 on January 9) O.P.+ 2,689 mm (Increase from initial level:3,415 mm, 44 mm increase since 16:00 on January 9) O.P.+ 4,273 mm (Water level from floor:477 mm, No change since 16:00 on January 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:33 on January 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.