

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 10)**

Water Level of the accumulated water (at 16:00 on January 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,098 mm (20 mm increase since 7:00 on January 10)	O.P.+ 2,987 mm (10 mm decrease since 7:00 on January 10)	—
	Water level of Turbine Building	O.P.+ 2,740 mm (1 mm decrease since 7:00 on January 10)	O.P.+ 3,109 mm (19 mm increase since 7:00 on January 10)	O.P.+ 2,824 mm (11 mm decrease since 7:00 on January 10)	O.P.+ 2,866 mm (11 mm decrease since 7:00 on January 10)
	Water level of Reactor Building	O.P.+ 4,065 mm (11 mm increase since 7:00 on January 10)	O.P.+ 3,369 mm (17 mm increase since 7:00 on January 10)	O.P.+ 3,014 mm (11 mm decrease since 7:00 on January 10)	O.P.+ 2,882 mm (8 mm decrease since 7:00 on January 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,727 mm (Increase from initial level:4,944 mm, 1 mm increase since 7:00 on January 10) O.P.+ 2,716 mm (Increase from initial level:3,442 mm, 27 mm increase since 7:00 on January 10) O.P.+ 4,273 mm (Water level from floor:477 mm, No change since 7:00 on January 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:33 on January 8   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.