

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 11)**

Water Level of the accumulated water (at 7:00 on January 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,132 mm (34 mm increase since 16:00 on January 10)	O.P.+ 2,969 mm (18 mm decrease since 16:00 on January 10)	—
	Water level of Turbine Building	O.P.+ 2,740 mm (No change since 16:00 on January 10)	O.P.+ 3,137 mm (28 mm increase since 16:00 on January 10)	O.P.+ 2,806 mm (18 mm decrease since 16:00 on January 10)	O.P.+ 2,849 mm (17 mm decrease since 16:00 on January 10)
	Water level of Reactor Building	O.P.+ 4,074 mm (9 mm increase since 16:00 on January 10)	O.P.+ 3,396 mm (27 mm increase since 16:00 on January 10)	O.P.+ 2,994 mm (20 mm decrease since 16:00 on January 10)	O.P.+ 2,866 mm (16 mm decrease since 16:00 on January 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,730 mm (Increase from initial level:4,947 mm, 3 mm increase since 16:00 on January 10) O.P.+ 2,762 mm (Increase from initial level:3,488 mm, 46 mm increase since 16:00 on January 10) O.P.+ 4,273 mm (Water level from floor:477 mm, No change since 16:00 on January 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:33 on January 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.