

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 11)**

Water Level of the accumulated water (at 16:00 on January 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,139 mm (7 mm increase since 7:00 on January 11)	O.P.+ 2,960 mm (9 mm decrease since 7:00 on January 11)	—
	Water level of Turbine Building	O.P.+ 2,740 mm (No change since 7:00 on January 11)	O.P.+ 3,143 mm (6 mm increase since 7:00 on January 11)	O.P.+ 2,807 mm (1 mm increase since 7:00 on January 11)	O.P.+ 2,839 mm (10 mm decrease since 7:00 on January 11)
	Water level of Reactor Building	O.P.+ 4,078 mm (4 mm increase since 7:00 on January 11)	O.P.+ 3,410 mm (14 mm increase since 7:00 on January 11)	O.P.+ 2,989 mm (5 mm decrease since 7:00 on January 11)	O.P.+ 2,854 mm (12 mm decrease since 7:00 on January 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,731 mm (Increase from initial level:4,948 mm, 1 mm increase since 7:00 on January 11) O.P.+ 2,798 mm (Increase from initial level:3,524 mm, 36 mm increase since 7:00 on January 11) O.P.+ 4,273 mm (Water level from floor:477 mm, No change since 7:00 on January 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:55 on January 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on December 18)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:33 on January 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:53, January 11, the desalination system 3 was suspended for replacing the damaged vent pipe. At 12:53 PM on the same day, operation was restarted after repair.				

For quick publication of the data of water level, values are provided as reference values.