

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 15)**

|   |  |  |   |   |  |
|---|--|--|---|---|--|
| Water Level of the accumulated water<br>(at 7:00 on January 15) |  | Unit 1   | Unit 2  | Unit 3  | Unit 4   |
|   | Water level of Vertical Shaft  | Unmeasurable due to drawdown of water level<br>(Less than O.P.+ 850 mm)  | O.P.+ 3,008 mm<br>(51 mm increase since 16:00 on January 14)  | O.P.+ 3,070 mm<br>(5 mm increase since 16:00 on January 14) | —  |
|   | Water level of Turbine Building  | O.P.+ 2,743 mm<br>(1 mm increase since 16:00 on January 14)  | O.P.+ 3,028 mm<br>(43 mm increase since 16:00 on January 14)  | O.P.+ 2,972 mm<br>(2 mm decrease since 16:00 on January 14) | O.P.+ 2,910 mm<br>(23 mm increase since 16:00 on January 14) |
|   | Water level of Reactor Building  | O.P.+ 4,021 mm<br>(12 mm decrease since 16:00 on January 14)   | O.P.+ 3,293 mm<br>(34 mm increase since 16:00 on January 14)  | O.P.+ 3,159 mm<br>(6 mm decrease since 16:00 on January 14) | O.P.+ 2,914 mm<br>(20 mm increase since 16:00 on January 14) |
|   | Water level of each building in the Centralized Radiation Waste Treatment Facility   | Process Main Building<br>High Temperature Incinerator Building<br>On-site Bunker Building  | O.P.+ 3,745 mm (Increase from initial level:4,962 mm, 3 mm increase since 16:00 on January 14)<br>O.P.+ 2,103 mm (Increase from initial level:2,829 mm, 298 mm decrease since 16:00 on January 14)<br>O.P.+ 4,275 mm (Water level from floor:479 mm, No change since 16:00 on January 14) |   |  |
| Situation of transfer of the accumulated water                  |  | Unit 1   | Unit 2  | Unit 3  | Unit 4   |
|   |  | —  | —   | —   | —  |
|   |  | Unit 5 and 6   |   |   |  |
|   |  |  |   |   |  |
| Operation condition of water treatment facility                 |  | Cesium Adsorption Apparatus: Since 16:46 on December 7   Suspended<br>2nd Cesium Adsorption Apparatus (Sarry): Since 9:00 on January 15   Suspended<br>Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance<br>Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance |   |   |  |
| Notes   | - At 9:00 AM on January 15, we stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. It will be stopped until January 23 in order to conduct the inspection for confirming the soundness of pipes etc. (non-destructive inspection). |  |   |   |  |

For quick publication of the data of water level, values are provided as reference values.