

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 15)**

Water Level of the accumulated water (at 16:00 on January 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,034 mm (26 mm increase since 7:00 on January 15)	O.P.+ 3,070 mm (No change since 7:00 on January 15)	—
	Water level of Turbine Building	O.P.+ 2,744 mm (1 mm increase since 7:00 on January 15)	O.P.+ 3,050 mm (22 mm increase since 7:00 on January 15)	O.P.+ 2,963 mm (9 mm decrease since 7:00 on January 15)	O.P.+ 2,921 mm (11 mm increase since 7:00 on January 15)
	Water level of Reactor Building	O.P.+ 4,022 mm (1 mm increase since 7:00 on January 15)	O.P.+ 3,313 mm (20 mm increase since 7:00 on January 15)	O.P.+ 3,158 mm (1 mm decrease since 7:00 on January 15)	O.P.+ 2,927 mm (13 mm increase since 7:00 on January 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,746 mm (Increase from initial level:4,963 mm, 1 mm increase since 7:00 on January 15) O.P.+ 2,131 mm (Increase from initial level:2,857 mm, 28 mm increase since 7:00 on January 15) O.P.+ 4,275 mm (Water level from floor:479 mm, No change since 7:00 on January 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 9:00 on January 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.