

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 16)**

Water Level of the accumulated water (at 7:00 on January 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,073 mm (39 mm increase since 16:00 on January 15)	O.P.+ 3,076 mm (6 mm increase since 16:00 on January 15)	—
	Water level of Turbine Building	O.P.+ 2,743 mm (1 mm decrease since 16:00 on January 15)	O.P.+ 3,084 mm (34 mm increase since 16:00 on January 15)	O.P.+ 2,963 mm (No change since 16:00 on January 15)	O.P.+ 2,936 mm (15 mm increase since 16:00 on January 15)
	Water level of Reactor Building	O.P.+ 4,032 mm (10 mm increase since 16:00 on January 15)	O.P.+ 3,346 mm (33 mm increase since 16:00 on January 15)	O.P.+ 3,160 mm (2 mm increase since 16:00 on January 15)	O.P.+ 2,942 mm (15 mm increase since 16:00 on January 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,749 mm (Increase from initial level:4,966 mm, 3 mm increase since 16:00 on January 15) O.P.+ 2,194 mm (Increase from initial level:2,920 mm, 63 mm increase since 16:00 on January 15) O.P.+ 4,275 mm (Water level from floor:479 mm, No change since 16:00 on January 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 9:00 on January 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.