

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 17)**

Water Level of the accumulated water (at 7:00 on January 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,132 mm (35 mm increase since 16:00 on January 16)	O.P.+ 3,090 mm (10 mm increase since 16:00 on January 16)	—
	Water level of Turbine Building	O.P.+ 2,744 mm (No change since 16:00 on January 16)	O.P.+ 3,135 mm (32 mm increase since 16:00 on January 16)	O.P.+ 2,979 mm (9 mm increase since 16:00 on January 16)	O.P.+ 2,955 mm (11 mm increase since 16:00 on January 16)
	Water level of Reactor Building	O.P.+ 4,064 mm (24 mm increase since 16:00 on January 16)	O.P.+ 3,399 mm (34 mm increase since 16:00 on January 16)	O.P.+ 3,174 mm (9 mm increase since 16:00 on January 16)	O.P.+ 2,959 mm (10 mm increase since 16:00 on January 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,755 mm (Increase from initial level:4,972 mm, 3 mm increase since 16:00 on January 16) O.P.+ 2,292 mm (Increase from initial level:3,018 mm, 61 mm increase since 16:00 on January 16) O.P.+ 4,276 mm (Water level from floor:480 mm, No change since 16:00 on January 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 9:00 on January 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.