

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 17)**

Water Level of the accumulated water (at 16:00 on January 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,155 mm (23 mm increase since 7:00 on January 17)	O.P.+ 3,096 mm (6 mm increase since 7:00 on January 17)	—
	Water level of Turbine Building	O.P.+ 2,744 mm (No change since 7:00 on January 17)	O.P.+ 3,153 mm (18 mm increase since 7:00 on January 17)	O.P.+ 2,981 mm (2 mm increase since 7:00 on January 17)	O.P.+ 2,962 mm (7 mm increase since 7:00 on January 17)
	Water level of Reactor Building	O.P.+ 4,078 mm (14 mm increase since 7:00 on January 17)	O.P.+ 3,417 mm (18 mm increase since 7:00 on January 17)	O.P.+ 3,180 mm (6 mm increase since 7:00 on January 17)	O.P.+ 2,967 mm (8 mm increase since 7:00 on January 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,756 mm (Increase from initial level:4,973 mm, 1 mm increase since 7:00 on January 17) O.P.+ 2,332 mm (Increase from initial level:3,058 mm, 40 mm increase since 7:00 on January 17) O.P.+ 4,276 mm (Water level from floor:480 mm, No change since 7:00 on January 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 9:00 on January 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.