

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 18)**

|   |  |  |  |  |   |
|---|--|--|--|--|---|
| Water Level of the accumulated water<br>(at 7:00 on January 18) |  | Unit 1   | Unit 2   | Unit 3   | Unit 4  |
|   | Water level of Vertical Shaft  | Unmeasurable due to drawdown of water level<br>(Less than O.P.+ 850 mm)  | O.P.+ 3,188 mm<br>(33 mm increase since 16:00 on January 17)   | O.P.+ 3,105 mm<br>(9 mm increase since 16:00 on January 17)  | —   |
|   | Water level of Turbine Building  | O.P.+ 2,745 mm<br>(1 mm increase since 16:00 on January 17)  | O.P.+ 3,181 mm<br>(28 mm increase since 16:00 on January 17)   | O.P.+ 2,995 mm<br>(14 mm increase since 16:00 on January 17) | O.P.+ 2,970 mm<br>(8 mm increase since 16:00 on January 17) |
|   | Water level of Reactor Building  | O.P.+ 4,105 mm<br>(27 mm increase since 16:00 on January 17)   | O.P.+ 3,447 mm<br>(30 mm increase since 16:00 on January 17)   | O.P.+ 3,191 mm<br>(11 mm increase since 16:00 on January 17) | O.P.+ 2,974 mm<br>(7 mm increase since 16:00 on January 17) |
|   | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building<br>High Temperature Incinerator Building<br>On-site Bunker Building  | O.P.+ 3,760 mm (Increase from initial level:4,977 mm, 4 mm increase since 16:00 on January 17)<br>O.P.+ 2,394 mm (Increase from initial level:3,120 mm, 62 mm increase since 16:00 on January 17)<br>O.P.+ 4,276 mm (Water level from floor:480 mm, No change since 16:00 on January 17) |  |   |
| Situation of transfer of the accumulated water                  |  | Unit 1   | Unit 2   | Unit 3   | Unit 4  |
|   |  | —  | —  | —  | —   |
|   |  | Unit 5 and 6   |  |  |   |
|   |  |  |  |  |   |
| Operation condition of water treatment facility                 |  | Cesium Adsorption Apparatus: Since 16:46 on December 7   Suspended<br>2nd Cesium Adsorption Apparatus (Sarry): Since 9:00 on January 15   Suspended<br>Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance<br>Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance |  |  |   |
| Notes   |  |  |  |  |   |

For quick publication of the data of water level, values are provided as reference values.