

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 18)**

Water Level of the accumulated water (at 16:00 on January 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,209 mm (21 mm increase since 7:00 on January 18)	O.P.+ 3,104 mm (1 mm decrease since 7:00 on January 18)	—
	Water level of Turbine Building	O.P.+ 2,744 mm (1 mm decrease since 7:00 on January 18)	O.P.+ 3,199 mm (18 mm increase since 7:00 on January 18)	O.P.+ 2,992 mm (3 mm decrease since 7:00 on January 18)	O.P.+ 2,975 mm (5 mm increase since 7:00 on January 18)
	Water level of Reactor Building	O.P.+ 4,120 mm (15 mm increase since 7:00 on January 18)	O.P.+ 3,465 mm (18 mm increase since 7:00 on January 18)	O.P.+ 3,190 mm (1 mm decrease since 7:00 on January 18)	O.P.+ 2,979 mm (5 mm increase since 7:00 on January 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,789 mm (Increase from initial level:5,006 mm, 29 mm increase since 7:00 on January 18) O.P.+ 2,431 mm (Increase from initial level:3,157 mm, 37 mm increase since 7:00 on January 18) O.P.+ 4,276 mm (Water level from floor:480 mm, No change since 7:00 on January 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 13:48 on January 18)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 9:00 on January 15   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.