

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 21)**

Water Level of the accumulated water (at 7:00 on January 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,245 mm (52 mm decrease since 16:00 on January 20)	O.P.+ 3,059 mm (7 mm increase since 16:00 on January 20)	—
	Water level of Turbine Building	O.P.+ 2,746 mm (No change since 16:00 on January 20)	O.P.+ 3,230 mm (46 mm decrease since 16:00 on January 20)	O.P.+ 2,943 mm (24 mm increase since 16:00 on January 20)	O.P.+ 2,927 mm (4 mm decrease since 16:00 on January 20)
	Water level of Reactor Building	O.P.+ 4,188 mm (5 mm increase since 16:00 on January 20)	O.P.+ 3,510 mm (38 mm decrease since 16:00 on January 20)	O.P.+ 3,139 mm (35 mm increase since 16:00 on January 20)	O.P.+ 2,938 mm (3 mm decrease since 16:00 on January 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,710 mm (Increase from initial level:5,927 mm, 190 mm increase since 16:00 on January 20) O.P.+ 2,681 mm (Increase from initial level:3,407 mm, 58 mm increase since 16:00 on January 20) O.P.+ 4,276 mm (Water level from floor:480 mm, No change since 16:00 on January 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:31 on January 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 13:48 on January 18)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 9:00 on January 15   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.