

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 21)**

Water Level of the accumulated water (at 16:00 on January 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,218 mm (27 mm decrease since 7:00 on January 21)	O.P.+ 3,065 mm (6 mm increase since 7:00 on January 21)	—
	Water level of Turbine Building	O.P.+ 2,746 mm (No change since 7:00 on January 21)	O.P.+ 3,206 mm (24 mm decrease since 7:00 on January 21)	O.P.+ 2,949 mm (6 mm increase since 7:00 on January 21)	O.P.+ 2,931 mm (4 mm increase since 7:00 on January 21)
	Water level of Reactor Building	O.P.+ 4,185 mm (3 mm decrease since 7:00 on January 21)	O.P.+ 3,490 mm (20 mm decrease since 7:00 on January 21)	O.P.+ 3,148 mm (9 mm increase since 7:00 on January 21)	O.P.+ 2,940 mm (2 mm increase since 7:00 on January 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,799 mm (Increase from initial level:6,016 mm, 89 mm increase since 7:00 on January 21) O.P.+ 2,715 mm (Increase from initial level:3,441 mm, 34 mm increase since 7:00 on January 21) O.P.+ 4,276 mm (Water level from floor:480 mm, No change since 7:00 on January 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:31 on January 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 13:48 on January 18)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 9:00 on January 15   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.