

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 22)**

Water Level of the accumulated water (at 7:00 on January 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,178 mm (40 mm decrease since 16:00 on January 21)	O.P.+ 3,077 mm (12 mm increase since 16:00 on January 21)	—
	Water level of Turbine Building	O.P.+ 2,747 mm (1 mm increase since 16:00 on January 21)	O.P.+ 3,171 mm (35 mm decrease since 16:00 on January 21)	O.P.+ 2,961 mm (12 mm increase since 16:00 on January 21)	O.P.+ 2,942 mm (11 mm increase since 16:00 on January 21)
	Water level of Reactor Building	O.P.+ 4,176 mm (9 mm decrease since 16:00 on January 21)	O.P.+ 3,459 mm (31 mm decrease since 16:00 on January 21)	O.P.+ 3,162 mm (14 mm increase since 16:00 on January 21)	O.P.+ 2,949 mm (9 mm increase since 16:00 on January 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,946 mm (Increase from initial level:6,163 mm, 147 mm increase since 16:00 on January 21) O.P.+ 2,846 mm (Increase from initial level:3,572 mm, 131 mm increase since 16:00 on January 21) O.P.+ 4,276 mm (Water level from floor:480 mm, No change since 16:00 on January 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:31 on January 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 13:48 on January 18)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:46 on December 7 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 9:00 on January 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.