

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 22)**

Water Level of the accumulated water (at 16:00 on January 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,156 mm (22 mm decrease since 7:00 on January 22)	O.P.+ 3,086 mm (9 mm increase since 7:00 on January 22)	—
	Water level of Turbine Building	O.P.+ 2,747 mm (No change since 7:00 on January 22)	O.P.+ 3,153 mm (18 mm decrease since 7:00 on January 22)	O.P.+ 2,973 mm (12 mm increase since 7:00 on January 22)	O.P.+ 2,949 mm (7 mm increase since 7:00 on January 22)
	Water level of Reactor Building	O.P.+ 4,187 mm (11 mm increase since 7:00 on January 22)	O.P.+ 3,447 mm (12 mm decrease since 7:00 on January 22)	O.P.+ 3,173 mm (11 mm increase since 7:00 on January 22)	O.P.+ 2,955 mm (6 mm increase since 7:00 on January 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,969 mm (Increase from initial level:6,186 mm, 23 mm increase since 7:00 on January 22) O.P.+ 2,880 mm (Increase from initial level:3,606 mm, 34 mm increase since 7:00 on January 22) O.P.+ 4,278 mm (Water level from floor:482 mm, 2 mm increase since 7:00 on January 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:31 on January 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 13:48 on January 18)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:15 on January 22 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:00 on January 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* According to suspension of 2nd Cesium Adsorption Apparatus (Sarry) and water level of Turbine Building.etc, we started the Cesium Adsorption Apparatus at 10:37 AM on January 22, , and the steady flow rate was achieved at 11:15 AM on the same day.				

For quick publication of the data of water level, values are provided as reference values.