

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 23)**

Water Level of the accumulated water (at 7:00 on January 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,120 mm (36 mm decrease since 16:00 on January 22)	O.P.+ 3,097 mm (11 mm increase since 16:00 on January 22)	—
	Water level of Turbine Building	O.P.+ 2,749 mm (2 mm increase since 16:00 on January 22)	O.P.+ 3,121 mm (32 mm decrease since 16:00 on January 22)	O.P.+ 2,988 mm (15 mm increase since 16:00 on January 22)	O.P.+ 2,961 mm (12 mm increase since 16:00 on January 22)
	Water level of Reactor Building	O.P.+ 4,204 mm (17 mm increase since 16:00 on January 22)	O.P.+ 3,410 mm (37 mm decrease since 16:00 on January 22)	O.P.+ 3,187 mm (14 mm increase since 16:00 on January 22)	O.P.+ 2,966 mm (11 mm increase since 16:00 on January 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,929 mm (Increase from initial level:6,146 mm, 40 mm decrease since 16:00 on January 22) O.P.+ 2,957 mm (Increase from initial level:3,683 mm, 77 mm increase since 16:00 on January 22) O.P.+ 4,278 mm (Water level from floor:482 mm, No change since 16:00 on January 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:31 on January 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 13:48 on January 18)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:15 on January 22 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:00 on January 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.