

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 23)**

Water Level of the accumulated water (at 16:00 on January 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,113 mm (7 mm decrease since 7:00 on January 23)	O.P.+ 3,104 mm (7 mm increase since 7:00 on January 23)	—
	Water level of Turbine Building	O.P.+ 2,748 mm (1 mm decrease since 7:00 on January 23)	O.P.+ 3,114 mm (7 mm decrease since 7:00 on January 23)	O.P.+ 2,990 mm (2 mm increase since 7:00 on January 23)	O.P.+ 2,968 mm (7 mm increase since 7:00 on January 23)
	Water level of Reactor Building	O.P.+ 4,203 mm (1 mm decrease since 7:00 on January 23)	O.P.+ 3,392 mm (18 mm decrease since 7:00 on January 23)	O.P.+ 3,193 mm (6 mm increase since 7:00 on January 23)	O.P.+ 2,974 mm (8 mm increase since 7:00 on January 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,890 mm (Increase from initial level:6,107 mm, 39 mm decrease since 7:00 on January 23) O.P.+ 3,005 mm (Increase from initial level:3,731 mm, 48 mm increase since 7:00 on January 23) O.P.+ 4,278 mm (Water level from floor:482 mm, No change since 7:00 on January 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 13:31 on January 20 to 14:05 on January 23)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 13:48 on January 18 to 14:15 on January 23)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:15 on January 22 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:00 on January 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.