

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 24)**

Water Level of the accumulated water (at 7:00 on January 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,163 mm (50 mm increase since 16:00 on January 23)	O.P.+ 3,114 mm (10 mm increase since 16:00 on January 23)	—
	Water level of Turbine Building	O.P.+ 2,749 mm (1 mm increase since 16:00 on January 23)	O.P.+ 3,158 mm (44 mm increase since 16:00 on January 23)	O.P.+ 3,001 mm (11 mm increase since 16:00 on January 23)	O.P.+ 2,979 mm (11 mm increase since 16:00 on January 23)
	Water level of Reactor Building	O.P.+ 4,204 mm (1 mm increase since 16:00 on January 23)	O.P.+ 3,425 mm (33 mm increase since 16:00 on January 23)	O.P.+ 3,207 mm (14 mm increase since 16:00 on January 23)	O.P.+ 2,983 mm (9 mm increase since 16:00 on January 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,704 mm (Increase from initial level:5,921 mm, 186 mm decrease since 16:00 on January 23) O.P.+ 3,083 mm (Increase from initial level:3,809 mm, 78 mm increase since 16:00 on January 23) O.P.+ 4,278 mm (Water level from floor:482 mm, No change since 16:00 on January 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:15 on January 22 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 9:00 on January 15 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.