

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 25)**

Water Level of the accumulated water (at 7:00 on January 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,236 mm (46 mm increase since 16:00 on January 24)	O.P.+ 3,098 mm (11 mm decrease since 16:00 on January 24)	—
	Water level of Turbine Building	O.P.+ 2,698 mm (22 mm decrease since 16:00 on January 24)	O.P.+ 3,220 mm (38 mm increase since 16:00 on January 24)	O.P.+ 2,955 mm (34 mm decrease since 16:00 on January 24)	O.P.+ 2,973 mm (9 mm decrease since 16:00 on January 24)
	Water level of Reactor Building	O.P.+ 4,223 mm (17 mm increase since 16:00 on January 24)	O.P.+ 3,491 mm (42 mm increase since 16:00 on January 24)	O.P.+ 3,164 mm (35 mm decrease since 16:00 on January 24)	O.P.+ 2,980 mm (8 mm decrease since 16:00 on January 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,644 mm (Increase from initial level:5,861 mm, 4 mm increase since 16:00 on January 24) O.P.+ 3,086 mm (Increase from initial level:3,812 mm, 32 mm decrease since 16:00 on January 24) O.P.+ 4,279 mm (Water level from floor:483 mm, 1 mm increase since 16:00 on January 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:03 on January 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:30 on January 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:07 on January 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	In our previous report (as of 6:00 PM on January 24, 2012), we announced "2nd Cesium Adsorption Apparatus (Sarry): Since 12:17 on January 25 In operation." We correct it as "Since 12:07 on January 24 In operation." We sincerely apologize for the mistake.				

For quick publication of the data of water level, values are provided as reference values.