

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 25)**

Water Level of the accumulated water (at 16:00 on January 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,261 mm (25 mm increase since 7:00 on January 25)	O.P.+ 3,090 mm (8 mm decrease since 7:00 on January 25)	—
	Water level of Turbine Building	O.P.+ 2,700 mm (2 mm increase since 7:00 on January 25)	O.P.+ 3,241 mm (21 mm increase since 7:00 on January 25)	O.P.+ 2,943 mm (12 mm decrease since 7:00 on January 25)	O.P.+ 2,965 mm (8 mm decrease since 7:00 on January 25)
	Water level of Reactor Building	O.P.+ 4,237 mm (14 mm increase since 7:00 on January 25)	O.P.+ 3,512 mm (21 mm increase since 7:00 on January 25)	O.P.+ 3,150 mm (14 mm decrease since 7:00 on January 25)	O.P.+ 2,973 mm (7 mm decrease since 7:00 on January 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,645 mm (Increase from initial level:5,862 mm, 1 mm increase since 7:00 on January 25) O.P.+ 3,081 mm (Increase from initial level:3,807 mm, 5 mm decrease since 7:00 on January 25) O.P.+ 4,279 mm (Water level from floor:483 mm, No change since 7:00 on January 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:03 on January 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:30 on January 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:07 on January 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.