

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 28)**

Water Level of the accumulated water (at 7:00 on January 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,313 mm (50 mm decrease since 16:00 on January 27)	O.P.+ 3,044 mm (7 mm increase since 16:00 on January 27)	—
	Water level of Turbine Building	O.P.+ 2,705 mm (2 mm increase since 16:00 on January 27)	O.P.+ 3,286 mm (43 mm decrease since 16:00 on January 27)	O.P.+ 2,925 mm (34 mm increase since 16:00 on January 27)	O.P.+ 2,909 mm (4 mm decrease since 16:00 on January 27)
	Water level of Reactor Building	O.P.+ 4,300 mm (No change since 16:00 on January 27)	O.P.+ 3,570 mm (32 mm decrease since 16:00 on January 27)	O.P.+ 3,123 mm (38 mm increase since 16:00 on January 27)	O.P.+ 2,920 mm (5 mm decrease since 16:00 on January 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,652 mm (Increase from initial level:5,869 mm, 3 mm increase since 16:00 on January 27) O.P.+ 2,974 mm (Increase from initial level:3,700 mm, 23 mm decrease since 16:00 on January 27) O.P.+ 4,280 mm (Water level from floor:484 mm, 1 mm increase since 16:00 on January 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:47 on January 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:03 on January 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:30 on January 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:07 on January 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.