

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 29)**

Water Level of the accumulated water (at 7:00 on January 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,251 mm (38 mm decrease since 16:00 on January 28)	O.P.+ 3,063 mm (12 mm increase since 16:00 on January 28)	—
	Water level of Turbine Building	O.P.+ 2,705 mm (No change since 16:00 on January 28)	O.P.+ 3,233 mm (32 mm decrease since 16:00 on January 28)	O.P.+ 2,945 mm (14 mm increase since 16:00 on January 28)	O.P.+ 2,925 mm (11 mm increase since 16:00 on January 28)
	Water level of Reactor Building	O.P.+ 4,277 mm (13 mm decrease since 16:00 on January 28)	O.P.+ 3,518 mm (30 mm decrease since 16:00 on January 28)	O.P.+ 3,147 mm (14 mm increase since 16:00 on January 28)	O.P.+ 2,933 mm (9 mm increase since 16:00 on January 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,653 mm (Increase from initial level:5,870 mm, 1 mm increase since 16:00 on January 28) O.P.+ 2,949 mm (Increase from initial level:3,675 mm, 17 mm decrease since 16:00 on January 28) O.P.+ 4,281 mm (Water level from floor:485 mm, No change since 16:00 on January 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:47 on January 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:03 on January 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:30 on January 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:07 on January 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- From 9:48 AM to 5:50 PM on January 28, we started transferring water stored in Unit 1 Condensate Storage Tank to Unit 1 Waste Treatment Building as a part of the restoration work of Unit 1 Condensate Storage Tank. - At 6:57 AM on January 29, we started transferring water stored in Unit 1 Condensate Storage Tank to Unit 1 Waste Treatment Building.				

For quick publication of the data of water level, values are provided as reference values.