

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 29)**

Water Level of the accumulated water (at 16:00 on January 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,231 mm (20 mm decrease since 7:00 on January 29)	O.P.+ 3,068 mm (5 mm increase since 7:00 on January 29)	—
	Water level of Turbine Building	O.P.+ 2,706 mm (1 mm increase since 7:00 on January 29)	O.P.+ 3,215 mm (18 mm decrease since 7:00 on January 29)	O.P.+ 2,953 mm (8 mm increase since 7:00 on January 29)	O.P.+ 2,931 mm (6 mm increase since 7:00 on January 29)
	Water level of Reactor Building	O.P.+ 4,268 mm (9 mm decrease since 7:00 on January 29)	O.P.+ 3,499 mm (19 mm decrease since 7:00 on January 29)	O.P.+ 3,154 mm (7 mm increase since 7:00 on January 29)	O.P.+ 2,939 mm (6 mm increase since 7:00 on January 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,654 mm (Increase from initial level:5,871 mm, 1 mm increase since 7:00 on January 29) O.P.+ 2,939 mm (Increase from initial level:3,665 mm, 10 mm decrease since 7:00 on January 29) O.P.+ 4,281 mm (Water level from floor:485 mm, No change since 7:00 on January 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:47 on January 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:03 on January 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:30 on January 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:07 on January 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	· From 6:57 AM to 17:30 PM on January 29, transfer of water from Unit 1 Condensate Storage Tank to Unit1 Radiation Waste Treatment Building was conducted.				

For quick publication of the data of water level, values are provided as reference values.