

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 30)**

Water Level of the accumulated water (at 16:00 on January 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,183 mm (17 mm decrease since 7:00 on January 30)	O.P.+ 3,083 mm (4 mm increase since 7:00 on January 30)	—
	Water level of Turbine Building	O.P.+ 2,706 mm (1 mm decrease since 7:00 on January 30)	O.P.+ 3,174 mm (14 mm decrease since 7:00 on January 30)	O.P.+ 2,969 mm (8 mm increase since 7:00 on January 30)	O.P.+ 2,947 mm (6 mm increase since 7:00 on January 30)
	Water level of Reactor Building	O.P.+ 4,249 mm (7 mm decrease since 7:00 on January 30)	O.P.+ 3,462 mm (13 mm decrease since 7:00 on January 30)	O.P.+ 3,173 mm (7 mm increase since 7:00 on January 30)	O.P.+ 2,954 mm (5 mm increase since 7:00 on January 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,656 mm (Increase from initial level:5,873 mm, 1 mm increase since 7:00 on January 30) O.P.+ 2,921 mm (Increase from initial level:3,647 mm, 5 mm decrease since 7:00 on January 30) O.P.+ 4,281 mm (Water level from floor:485 mm, No change since 7:00 on January 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:47 on January 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:03 on January 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:30 on January 24   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:07 on January 24   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	· At 6:48 AM on January 30, transfer of water from Unit 1 Condensate Storage Tank to Unit 1 Radiation Waste Treatment Building was started, and stopped at 4:37 PM on the same day. · At 6:00 PM on January 30, transfer of accumulated water from the Common Pool Duct to Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) was started				

For quick publication of the data of water level, values are provided as reference values.