

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 1)**

Water Level of the accumulated water (at 7:00 on February 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,108 mm (31 mm decrease since 16:00 on January 31)	O.P.+ 3,077 mm (10 mm increase since 16:00 on January 31)	—
	Water level of Turbine Building	O.P.+ 2,707 mm (1 mm increase since 16:00 on January 31)	O.P.+ 3,109 mm (25 mm decrease since 16:00 on January 31)	O.P.+ 2,997 mm (13 mm increase since 16:00 on January 31)	O.P.+ 2,972 mm (9 mm increase since 16:00 on January 31)
	Water level of Reactor Building	O.P.+ 4,212 mm (19 mm decrease since 16:00 on January 31)	O.P.+ 3,399 mm (24 mm decrease since 16:00 on January 31)	O.P.+ 3,201 mm (11 mm increase since 16:00 on January 31)	O.P.+ 2,977 mm (9 mm increase since 16:00 on January 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,662 mm (Increase from initial level:5,879 mm, 1 mm increase since 16:00 on January 31) O.P.+ 3,187 mm (Increase from initial level:3,913 mm, 82 mm decrease since 16:00 on January 31) O.P.+ 4,283 mm (Water level from floor:487 mm, 1 mm increase since 16:00 on January 31)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:47 on January 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:03 on January 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:30 on January 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:20 on January 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 6:41 AM on February 1, we started transferring water stored in Unit 1 Condensate Storage Tank to Unit 1 Waste Treatment Building.				

For quick publication of the data of water level, values are provided as reference values.