

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 1)**

Water Level of the accumulated water (at 16:00 on February 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,091 mm (17 mm decrease since 7:00 on February 1)	O.P.+ 3,082 mm (5 mm increase since 7:00 on February 1)	—
	Water level of Turbine Building	O.P.+ 2,706 mm (1 mm decrease since 7:00 on February 1)	O.P.+ 3,096 mm (13 mm decrease since 7:00 on February 1)	O.P.+ 3,000 mm (3 mm increase since 7:00 on February 1)	O.P.+ 2,978 mm (6 mm increase since 7:00 on February 1)
	Water level of Reactor Building	O.P.+ 4,203 mm (9 mm decrease since 7:00 on February 1)	O.P.+ 3,388 mm (11 mm decrease since 7:00 on February 1)	O.P.+ 3,207 mm (6 mm increase since 7:00 on February 1)	O.P.+ 2,983 mm (6 mm increase since 7:00 on February 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,663 mm (Increase from initial level:5,880 mm, 1 mm increase since 7:00 on February 1) O.P.+ 3,138 mm (Increase from initial level:3,864 mm, 49 mm decrease since 7:00 on February 1) O.P.+ 4,283 mm (Water level from floor:487 mm, No change since 7:00 on February 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:47 on January 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:03 on January 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:30 on January 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:20 on January 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	From 6:41 AM to 5:15 PM on February 1, the water stored in Unit 1 condensate water storage tank was transferred to Unit 1 Waste Treatment Building.				

※ For quick publication of the data of water level, values are provided as reference values.