

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 4)**

Water Level of the accumulated water (at 7:00 on February 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,234 mm (50 mm increase since 16:00 on February 3)	O.P.+ 3,046 mm (17 mm decrease since 16:00 on February 3)	—
	Water level of Turbine Building	O.P.+ 2,709 mm (No change since 16:00 on February 3)	O.P.+ 3,217 mm (42 mm increase since 16:00 on February 3)	O.P.+ 2,924 mm (23 mm decrease since 16:00 on February 3)	O.P.+ 2,953 mm (17 mm decrease since 16:00 on February 3)
	Water level of Reactor Building	O.P.+ 4,168 mm (3 mm decrease since 16:00 on February 3)	O.P.+ 3,488 mm (44 mm increase since 16:00 on February 3)	O.P.+ 3,132 mm (22 mm decrease since 16:00 on February 3)	O.P.+ 2,963 mm (14 mm decrease since 16:00 on February 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,669 mm (Increase from initial level:5,886 mm, 1 mm increase since 16:00 on February 3) O.P.+ 2,824 mm (Increase from initial level:3,550 mm, 61 mm decrease since 16:00 on February 3) O.P.+ 4,284 mm (Water level from floor:488 mm, No change since 16:00 on February 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:03 on January 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:30 on January 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:20 on January 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.