

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 4)**

Water Level of the accumulated water (at 16:00 on February 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,262 mm (28 mm increase since 7:00 on February 4)	O.P.+ 3,035 mm (11 mm decrease since 7:00 on February 4)	—
	Water level of Turbine Building	O.P.+ 2,710 mm (1 mm increase since 7:00 on February 4)	O.P.+ 3,242 mm (25 mm increase since 7:00 on February 4)	O.P.+ 2,912 mm (12 mm decrease since 7:00 on February 4)	O.P.+ 2,943 mm (10 mm decrease since 7:00 on February 4)
	Water level of Reactor Building	O.P.+ 4,176 mm (8 mm increase since 7:00 on February 4)	O.P.+ 3,513 mm (25 mm increase since 7:00 on February 4)	O.P.+ 3,120 mm (12 mm decrease since 7:00 on February 4)	O.P.+ 2,955 mm (8 mm decrease since 7:00 on February 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,670 mm (Increase from initial level:5,887 mm, 1 mm increase since 7:00 on February 4) O.P.+ 2,791 mm (Increase from initial level:3,517 mm, 33 mm decrease since 7:00 on February 4) O.P.+ 4,285 mm (Water level from floor:489 mm, 1 mm increase since 7:00 on February 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:03 on January 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:30 on January 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:20 on January 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 5:10 PM on February 4, we started transferring the accumulated water in the Common Pool duct to the Central Radioactive Waste Treatment Facility (High Temperature Incinerator Building).				

※ For quick publication of the data of water level, values are provided as reference values.