

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 5)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on February 5)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,306 mm (44 mm increase since 16:00 on February 4)	O.P.+ 3,018 mm (17 mm decrease since 16:00 on February 4)	—
	Water level of Turbine Building	O.P.+ 2,710 mm (No change since 16:00 on February 4)	O.P.+ 3,279 mm (37 mm increase since 16:00 on February 4)	O.P.+ 2,892 mm (20 mm decrease since 16:00 on February 4)	O.P.+ 2,926 mm (17 mm decrease since 16:00 on February 4)
	Water level of Reactor Building	O.P.+ 4,194 mm (18 mm increase since 16:00 on February 4)	O.P.+ 3,550 mm (37 mm increase since 16:00 on February 4)	O.P.+ 3,098 mm (22 mm decrease since 16:00 on February 4)	O.P.+ 2,939 mm (16 mm decrease since 16:00 on February 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,672 mm (Increase from initial level:5,889 mm, 2 mm increase since 16:00 on February 4) O.P.+ 2,777 mm (Increase from initial level:3,503 mm, 14 mm decrease since 16:00 on February 4) O.P.+ 4,285 mm (Water level from floor:489 mm, No change since 16:00 on February 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:03 on January 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility	Cesium Adsorption Apparatus: Since 12:30 on January 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:20 on January 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance				
Notes	From 5:10 PM on February 4 to 8:30 AM on February 5, we started transferring the accumulated water in the Common Pool duct to the Central Radioactive Waste Treatment Facility (High Temperature Incinerator Building).				

For quick publication of the data of water level, values are provided as reference values.