

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 5)**

Water Level of the accumulated water (at 16:00 on February 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,329 mm (23 mm increase since 7:00 on February 5)	O.P.+ 3,008 mm (10 mm decrease since 7:00 on February 5)	—
	Water level of Turbine Building	O.P.+ 2,710 mm (No change since 7:00 on February 5)	O.P.+ 3,298 mm (19 mm increase since 7:00 on February 5)	O.P.+ 2,880 mm (12 mm decrease since 7:00 on February 5)	O.P.+ 2,916 mm (10 mm decrease since 7:00 on February 5)
	Water level of Reactor Building	O.P.+ 4,205 mm (11 mm increase since 7:00 on February 5)	O.P.+ 3,568 mm (18 mm increase since 7:00 on February 5)	O.P.+ 3,086 mm (12 mm decrease since 7:00 on February 5)	O.P.+ 2,929 mm (10 mm decrease since 7:00 on February 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,672 mm (Increase from initial level:5,889 mm, No change since 7:00 on February 5) O.P.+ 2,753 mm (Increase from initial level:3,479 mm, 24 mm decrease since 7:00 on February 5) O.P.+ 4,284 mm (Water level from floor:488 mm, 1 mm decrease since 7:00 on February 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:03 on January 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:30 on January 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:20 on January 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.