

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 6)**

Water Level of the accumulated water (at 7:00 on February 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,363 mm (34 mm increase since 16:00 on February 5)	O.P.+ 2,991 mm (17 mm decrease since 16:00 on February 5)	—
	Water level of Turbine Building	O.P.+ 2,711 mm (1 mm increase since 16:00 on February 5)	O.P.+ 3,328 mm (30 mm increase since 16:00 on February 5)	O.P.+ 2,858 mm (22 mm decrease since 16:00 on February 5)	O.P.+ 2,899 mm (17 mm decrease since 16:00 on February 5)
	Water level of Reactor Building	O.P.+ 4,224 mm (19 mm increase since 16:00 on February 5)	O.P.+ 3,600 mm (32 mm increase since 16:00 on February 5)	O.P.+ 3,065 mm (21 mm decrease since 16:00 on February 5)	O.P.+ 2,913 mm (16 mm decrease since 16:00 on February 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,674 mm (Increase from initial level:5,891 mm, 2 mm increase since 16:00 on February 5) O.P.+ 2,705 mm (Increase from initial level:3,431 mm, 48 mm decrease since 16:00 on February 5) O.P.+ 4,285 mm (Water level from floor:489 mm, 1 mm increase since 16:00 on February 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:03 on January 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:30 on January 24   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:22 on February 6   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:22 AM on February 6, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.