

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 6)**

|   |   | Unit 1   | Unit 2   | Unit 3  | Unit 4   |
|---|---|--|--|---|--|
| Water Level of the accumulated water (at 16:00 on February 6) | Water level of Vertical Shaft   | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)   | O.P.+ 3,368 mm (5 mm increase since 7:00 on February 6)  | O.P.+ 2,980 mm (11 mm decrease since 7:00 on February 6)  | —  |
|   | Water level of Turbine Building   | O.P.+ 2,710 mm (1 mm decrease since 7:00 on February 6)  | O.P.+ 3,332 mm (4 mm increase since 7:00 on February 6)  | O.P.+ 2,860 mm (2 mm increase since 7:00 on February 6)   | O.P.+ 2,889 mm (10 mm decrease since 7:00 on February 6) |
|   | Water level of Reactor Building   | O.P.+ 4,238 mm (14 mm increase since 7:00 on February 6)   | O.P.+ 3,616 mm (16 mm increase since 7:00 on February 6)   | O.P.+ 3,062 mm (3 mm decrease since 7:00 on February 6)   | O.P.+ 2,903 mm (10 mm decrease since 7:00 on February 6) |
|   | Water level of each building in the Centralized Radiation Waste Treatment Facility  | Process Main Building<br>High Temperature Incinerator Building<br>On-site Bunker Building  | O.P.+ 4,675 mm (Increase from initial level:5,892 mm, 1 mm increase since 7:00 on February 6)<br>O.P.+ 2,858 mm (Increase from initial level:3,584 mm, 153 mm increase since 7:00 on February 6)<br>O.P.+ 4,285 mm (Water level from floor:489 mm, No change since 7:00 on February 6) |   |  |
| Situation of transfer of the accumulated water                |   | Unit 1   | Unit 2   | Unit 3  | Unit 4   |
|   |   | —  | Basement of Unit 2 Turbine Building<br>→Basement of Unit 3 Turbine Building<br>Currently being transferred (Since 13:42 on February 6)   | Basement of Unit 3 Turbine Building<br>→Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building)<br>Currently being transferred (Since 11:03 on January 24) | —  |
|   |   | Unit 5 and 6<br>—  |  |   |  |
| Operation condition of water treatment facility               |   | Cesium Adsorption Apparatus: Since 12:30 on January 24 Suspended<br>2nd Cesium Adsorption Apparatus (Sarry): Since 13:13 on February 6 In operation<br>Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance<br>Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance |  |   |  |
| Notes   | At 8:22 AM on February 6, the Second Cesium Absorption Apparatus (SARRY) was temporarily suspended for filter cleaning. At 12:28 PM on the same day, the apparatus was started after the cleaning was completed and the steady flow rate was achieved at 1:13 PM. |  |  |   |  |

※ For quick publication of the data of water level, values are provided as reference values.