

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 7)**

Water Level of the accumulated water (at 7:00 on February 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,321 mm (47 mm decrease since 16:00 on February 6)	O.P.+ 2,989 mm (9 mm increase since 16:00 on February 6)	—
	Water level of Turbine Building	O.P.+ 2,710 mm (No change since 16:00 on February 6)	O.P.+ 3,291 mm (41 mm decrease since 16:00 on February 6)	O.P.+ 2,898 mm (38 mm increase since 16:00 on February 6)	O.P.+ 2,885 mm (4 mm decrease since 16:00 on February 6)
	Water level of Reactor Building	O.P.+ 4,257 mm (19 mm increase since 16:00 on February 6)	O.P.+ 3,585 mm (31 mm decrease since 16:00 on February 6)	O.P.+ 3,099 mm (37 mm increase since 16:00 on February 6)	O.P.+ 2,898 mm (5 mm decrease since 16:00 on February 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,676 mm (Increase from initial level:5,893 mm, 1 mm increase since 16:00 on February 6) O.P.+ 2,794 mm (Increase from initial level:3,520 mm, 64 mm decrease since 16:00 on February 6) O.P.+ 4,285 mm (Water level from floor:489 mm, No change since 16:00 on February 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:42 on February 6)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:03 on January 24)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:30 on January 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:13 on February 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.